

2018年11月废水自动监测结果

QR-AH-12.14-2018

日期	COD(60mg/l)		NH3-N(15mg/l)		总氮(20mg/l)		废水流量t/d
	排放平均浓度 mg/l	排放量kg	排放平均浓度 mg/l	排放量kg	排放平均浓度 mg/l	排放量kg	
2018/11/1	14.82	13.44	8.23	7.44	8.56	7.75	905.65
2018/11/2	14.76	15.65	8.54	9.06	8.2	8.73	1060.86
2018/11/3	16.36	16.36	8.6	8.52	8.57	8.5	989.52
2018/11/4	17.52	17.52	8.23	8.38	7.56	7.69	1017.7
2018/11/5	14.95	15.3	7.78	7.95	7.79	7.99	1022.78
2018/11/6	15.45	15.77	7.18	7.33	7.93	8.08	1021.25
2018/11/7	14.02	6.96	6.44	3.22	8.1	4.01	496.21
2018/11/8	20.65	16.6	6.27	5.03	10.15	8.13	800.61
2018/11/9	23.32	25.3	6.49	7.07	10.62	11.51	1084.92
2018/11/10	17.76	18.46	5.87	6.11	10.9	11.3	1039.02
2018/11/11	16.66	17.61	6.12	6.49	10.66	11.29	1057.87
2018/11/12	17.56	18.1	6.06	6.28	10.64	10.97	1030.83
2018/11/13	32.86	26.85	5.35	4.68	9.61	7.6	970.27
2018/11/14	17.11	73.08	5.93	6.99	9.88	11.62	1176.42
2018/11/15	29.21	23.38	5.77	5.6	10.02	9.74	970.79
2018/11/16	21.04	18.48	5.8	5.05	10.22	8.98	878.59
2018/11/17	20.51	21.50	5.87	6.15	10.32	10.79	1047.83
2018/11/18	18.22	17.62	5.88	5.69	10.25	9.93	968.19
2018/11/19	17.83	17.52	5.83	5.72	10.09	9.91	981.81
2018/11/20	17.92	16.98	5.89	5.57	10.27	9.71	946.37
2018/11/21	17.59	16.95	5.87	5.66	10.52	10.15	962.53
2018/11/22	17.77	20.78	6.16	7.18	10.43	12.19	1168.44
2018/11/23	17.19	19.28	6.32	7.1	10.15	11.4	1121.81
2018/11/24	17.44	15.91	6.23	5.69	10.24	9.33	910.35
2018/11/25	19.99	19.09	6.08	5.78	10.35	9.9	954.79
2018/11/26	22.79	24.13	5.95	6.33	10.42	11.05	1059
2018/11/27	24.11	24.16	5.81	5.79	10.34	10.36	1001.66
2018/11/28	28.13	30.46	5.89	6.35	10.13	10.98	1082.77
2018/11/29	26.59	28.85	6.09	6.61	10.53	11.54	1084.94
2018/11/30	34.25	40.5	6.27	7.43	10.58	12.53	1182.81