

四川永祥股份有限公司2019年1月废水自动监测结果

QR-AH-12.14-2019

日期	COD(60mg/l)		NH3-N(15mg/l)		总氮(20mg/l)		废水流量t/d
	排放平均浓度 mg/l	排放量kg	排放平均浓度 mg/l	排放量kg	排放平均浓度 mg/l	排放量kg	
2019/1/1	27.01	24.48	7.07	6.46	9.94	8.99	906.59
2019/1/2	28.17	25.51	7.15	6.53	10.18	9.23	905.75
2019/1/3	35.48	35.04	7.04	6.95	9.2	9.08	987.69
2019/1/4	22.28	20.31	7.2	6.55	9.74	8.87	910.34
2019/1/5	20.64	22.71	7.19	7.92	9.64	10.59	1098.46
2019/1/6	19.73	18.78	7.15	6.81	9.59	9.13	950.73
2019/1/7	19.6	20.76	6.97	7.36	9.45	10	1058.24
2019/1/8	20.29	23.58	6.74	7.92	9.47	11.11	1174.1
2019/1/9	21.12	25.36	6.79	8.14	9.35	11.21	1200.23
2019/1/10	21.57	25.31	6.83	8	11.32	22.32	1173.51
2019/1/11	23.21	23.65	6.87	7.01	9.82	9.82	1017.91
2019/1/12	23.14	25.82	6.97	7.83	10.74	10.74	1115.39
2019/1/13	23.15	24.45	7.01	7.42	10.08	10.08	1057.49
2019/1/14	23.23	24.43	7.02	7.38	9.5	10	1052.37
2019/1/15	23.07	23.29	7.03	7.09	9.31	9.39	1009.4
2019/1/16	23.04	26.98	7.12	8.34	9.32	10.9	1170.46
2019/1/17	22.85	24.53	7.29	7.82	9.57	10.29	1074.01
2019/1/18	24.72	28.45	7.36	8.45	9.6	11.04	1150.13
2019/1/19	21.57	25.10	7.37	8.54	9.32	10.86	1162.68
2019/1/20	21.31	22.79	7.36	7.87	9.32	9.99	1069.82
2019/1/21	22.08	26.09	7.38	8.72	9.6	11.35	1181.43
2019/1/22	19.82	10.4	7.42	3.88	9.82	5.15	525.21
2019/1/23	20.04	20.69	7.39	7.64	9.81	10.14	1031.96
2019/1/24	19.87	19.51	7.56	7.47	9.74	9.59	983.12
2019/1/25	17.53	18.34	7.6	7.96	9.74	10.18	1046.09
2019/1/26	18.49	19.71	7.69	8.18	9.61	10.24	1066.68
2019/1/27	17.59	20.34	7.86	9.09	9.71	11.21	1155.92
2019/1/28	17.03	18.68	7.76	8.52	9.5	10.42	1097.98
2019/1/29	16.36	18.34	7.64	8.56	9.45	10.6	1120.02
2019/1/30	16.50	19.71	7.64	9.13	9.58	11.45	1194.3
2019/1/31	15.58	18.1	7.62	8.87	9.3	10.8	1162.47