

四川永祥股份有限公司2019年2月废水自动监测结果

QR-AH-12.14-2019

日期	COD(60mg/l)		NH3-N(15mg/l)		总氮(20mg/l)		废水流量t/d
	排放平均浓度 mg/l	排放量kg	排放平均浓度 mg/l	排放量kg	排放平均浓度 mg/l	排放量kg	
2019/2/1	14.3	16.65	7.61	8.87	9.26	10.79	1163.42
2019/2/2	13.5	13.73	7.56	7.67	9.21	9.33	1015.88
2019/2/3	14.00	14.42	7.65	7.87	9.18	9.43	1029.86
2019/2/4	13.71	13.36	7.73	7.58	9.17	8.93	974.62
2019/2/5	14.16	14.69	7.49	7.81	9.31	9.66	1038.06
2019/2/6	14.32	14.15	7.31	7.25	9.48	9.39	989.4
2019/2/7	15.42	12.68	7.4	6.09	9.93	8.17	822.31
2019/2/8	15.73	16.78	7.38	7.83	10.09	10.77	1066.32
2019/2/9	14.30	16.2	7.54	8.55	9.99	11.3	1132.1
2019/2/10	15.21	17.75	7.77	9.08	10.37	12.09	1166.69
2019/2/11	14.69	12.69	7.85	6.79	10.29	8.89	864.66
2019/2/12	15.51	13.59	7.78	6.82	9.94	8.7	874.54
2019/2/13	15.48	13.39	7.8	6.75	9.88	8.55	864.81
2019/2/14	16.62	17.82	7.96	8.53	10.25	10.98	1071.63
2019/2/15	16.76	17.41	8.05	8.34	10.55	10.95	1039.18
2019/2/16	16.7	17.54	8.12	8.53	10.81	11.39	1050.84
2019/2/17	17.22	13.67	7.82	6.2	10.87	8.61	792.57
2019/2/18	17.1	13.90	7.68	6.24	10.43	8.47	814.65
2019/2/19	20.3	20.04	7.01	6.92	9.56	9.45	987.85
2019/2/20	19.98	17.24	7.84	6.79	10.36	8.92	862.98
2019/2/21	19.81	18.14	7.85	7.23	10.56	9.66	915.69
2019/2/22	19.07	17.98	7.91	7.46	9.94	9.35	942.48
2019/2/23	18.13	16.08	7.86	7	9.58	8.52	887.39
2019/2/24	17.70	13.94	8.04	6.33	9.58	7.56	788.77
2019/2/25	17.75	18.62	8.2	8.6	9.81	10.27	1047.56
2019/2/26	19.74	18.28	8.36	7.76	10.53	9.25	924.22
2019/2/27	19.62	14.75	8.42	6.33	10.51	7.92	751.42
2019/2/28	20.03	16.12	8.45	6.78	10.65	8.55	803.42