

四川永祥股份有限公司2019年3月废水自动监测结果

QR-AH-12.14-2019

日期	COD(60mg/l)		NH3-N(15mg/l)		总氮(20mg/l)		废水流量t/d
	排放平均浓度 mg/l	排放量kg	排放平均浓度 mg/l	排放量kg	排放平均浓度 mg/l	排放量kg	
2019/3/1	19.95	14.76	8.45	6.23	10.78	7.98	739.34
2019/3/2	20.32	19.06	8.59	8.06	10.9	10.2	936.36
2019/3/3	19.16	17.09	8.77	7.76	11.09	9.86	891.49
2019/3/4	16.40	15.64	8.35	7.96	10.83	10.33	953.3
2019/3/5	16.64	17.57	7.88	8.36	10.76	11.4	1057.6
2019/3/6	18.47	19.48	7.56	7.98	10.72	11.33	1055.56
2019/3/7	17.95	17.09	7.68	7.31	10.91	10.4	951.34
2019/3/8	14.18	13.2	7.86	7.34	11.01	10.24	930.99
2019/3/9	14.07	12.8	7.56	6.86	10.37	9.43	908.83
2019/3/10	17.23	13.62	7.49	5.92	10.29	8.13	790.93
2019/3/11	17.04	17.68	7.8	8.08	10.64	11.04	1037.95
2019/3/12	30.70	34.68	6.72	7.6	11	12.41	1129.81
2019/3/13	15.91	15.92	7.66	7.71	10.35	10.37	1002.32
2019/3/14	15.47	16.82	7.92	8.68	10.63	11.64	1091.9
2019/3/15	24.54	27.83	8.49	9.61	9.25	10.49	1134.4
2019/3/16	15.13	12.10	9.76	7.81	9.32	7.44	798.53
2019/3/17	14.5	14.52	9.37	9.41	9.19	9.21	1002.05
2019/3/18	14.73	14.28	8.49	8.22	9.33	9.06	969.61
2019/3/19	14.17	14.24	9.02	9.03	9.87	9.88	1003.36
2019/3/20	14.3	13.12	8.55	7.85	9.44	8.63	916.13
2019/3/21	18.52	18.73	8.53	8.55	10.93	11.05	1004.2
2019/3/22	16.15	14.5	8.43	7.57	9.4	8.43	899.19
2019/3/23	14.67	16.13	8.94	9.82	9.85	10.81	1098.61
2019/3/24	14.62	14.6	8.67	8.67	9.03	9.05	1000.16
2019/3/25	14.56	12.6	8.44	7.28	9.04	7.84	864.83
2019/3/26	15.15	14.86	8.51	8.37	9.11	8.95	981.6
2019/3/27	14.84	13.65	8.65	7.95	8.77	8.07	919.34
2019/3/28	14.42	14.45	8.87	8.87	9.13	9.16	1002.85
2019/3/29	20.43	20.51	8.75	8.81	9.13	9.17	1004.28
2019/3/30	19.10	17.4	8.47	7.72	9.28	8.43	910.16
2019/3/31	17.47	14.99	8.5	7.36	8.49	7.52	859.08